













**POLICE DEPARTMENT**  
 611 LIVE OAK STREET

**TRANSITION PLAN**







ITEM #	SECTION #: GROUP	NON-COMPLIANCE DESCRIPTION	COMMENTS / SUGGESTED CORRECTIONS	PRIORITY	COST CODE	BUDGET COST	COMPL. DATE	PHOTOGRAPHS
1	208: Parking Spaces (Public Parking)	1. No van parking. 2. Accessible parking < 2 spaces. 3. Sign height < 60" above the ground.	1. Provide one (1) van accessible space with access aisle and two (2) accessible parking spaces. 2. Fifty-one (51) total public parking spaces. 3. Exterior lights are not working.	1	PK1 PK3	\$ 3,000		
2	404: Doors, Doorways & Gates (Entry Doors)	1. Door closes < 5 seconds.	1. Adjust door closure.	1	OL	\$ 150		
3	302: Floor & Ground Surfaces (Entry Doors)	1. Mats at doors are not secured to the floor.	1. Provide mats that are secured to floor.	2	MAT	\$ 200		
4	208: Parking Spaces (Employee, behind gated fence)	1. No accessible parking. 2. No van parking.	1. Provide one (1) van accessible space with access aisle and one (1) accessible parking space. 2. Thirty-two (32) total private parking spaces (employee/patrol car parking spaces).	1	PK1 PK3	\$ 2,100		
5	206: Accessible Routes (Employee, behind gated fence)	1. No accessible routes from employee parking.	1. Provide accessible access from north parking lot. 2. Install curb ramp.	1	CR1	\$ 700		
6	302: Floor & Ground Surfaces (Employee, behind gated fence)	1. Mats at doors are not secured to the floor.	1. Provide mats that are secured to floor. (± 4 each)	2	MAT	\$ 400		

**TRANSITION PLAN**

ITEM #	SECTION #: GROUP	NON-COMPLIANCE DESCRIPTION	COMMENTS / SUGGESTED CORRECTIONS	PRIORITY	COST CODE	BUDGET COST	COMPL. DATE	PHOTOGRAPHS
7	404: Doors, Doorways & Gates (Exterior Public front entrance to Courtroom)	1. Entry doors < 32" clearance.	1. Provide automatic door opener.	1	DO3	\$ 2,000		
8	206: Access Route (Courtroom)	1. Metal detectors < 32" wide.	1. Provide alternate means for scanning individuals who cannot pass through detectors.	2	-	-		
9	808: Courtrooms	1. Judge's benches and courtroom stations shall comply with 902 (clear space, knee and toe clearance, and work space height).	1. Provide accessible judge's bench when the need arises. 2. Wheelchair spaces are not required to be located in witness stand area where ramp or lift poses a hazard by obstructing means of egress.	2	-	-		
10	404: Doors, Doorways & Gates (Courtroom)	1. Door hardware. 2. Door closes < 5 seconds. 3. Door opening force > 5 lbs. 4. Double doors into courtroom < 32" width clearance.	1. Remove and replace door knobs with levers. (± 10 each) 2. Adjust door closures. 3. Provide automatic door open device.	2	DO3 OL	\$ 4,500		
11	904.4: Sales & Service Counter (1st and 2nd Floor Lobby Counter)	1. Counter height > 36" above floor.	1. Provide accessible sales/service counter 34" max above floor. 2. Parallel approach.	2	SWC1	\$ 1,000		
12	904.4: Sales & Service Counter (Booking Counter)	1. Counter height > 36" above floor.	1. Provide accessible sales/service counter 34" max above floor. 2. Parallel approach.	2	SWC1	\$ 1,000		

**POLICE DEPARTMENT**  
 611 LIVE OAK STREET

**TRANSITION PLAN**

ITEM #	SECTION #: GROUP	NON-COMPLIANCE DESCRIPTION	COMMENTS / SUGGESTED CORRECTIONS	PRIORITY	COST CODE	BUDGET COST	COMPL. DATE	PHOTOGRAPHS
13	404: Doors, Doorways & Gates	<ol style="list-style-type: none"> <li>1. Double doors &lt; 32" wide clearance.</li> <li>2. Door hardware (handles &amp; pulls).</li> <li>3. Opening force &gt; 5 lbs.</li> <li>4. Closing &lt; 5 seconds.</li> </ol>	<ol style="list-style-type: none"> <li>1. Remove and replace door knobs with levers. (± 1 each)</li> <li>2. Adjust door closures.</li> <li>3. Remove and replace double doors with one door 36" wide min. (± 2 each)</li> </ol>	2	DO2 DO3	\$ 20,000		
14	703: Signs	<ol style="list-style-type: none"> <li>1. Interior signs are non-compliant.</li> </ol>	<ol style="list-style-type: none"> <li>1. Provide accessible signage. (± 65 each)</li> <li>2. Provide directional signage to restrooms.</li> </ol>	2	IS1	\$ 6,500		
15	602: Drinking Fountains	<ol style="list-style-type: none"> <li>1. No high-low fountains.</li> <li>2. Several fountains are not in working order.</li> <li>3. Second floor fountain near lobby located at back side of door.</li> </ol>	<ol style="list-style-type: none"> <li>1. Provide high-low drinking fountains. (± 2 each)</li> <li>2. Repair/replace non-working fountains.</li> <li>3. Relocate second floor fountain from door.</li> </ol>	4	EDF2	\$ 4,000		
16	803: Dressing, Fitting & Locker Rooms	<ol style="list-style-type: none"> <li>1. Handle on lockers</li> <li>2. Showers</li> <li>3. Coat hooks</li> </ol>	<ol style="list-style-type: none"> <li>1. Evaluate policy regarding accessible locker needs/requirements. If required, provide accessible lockers.</li> </ol>	4	OL	\$ 800		
17	604: Water Closets & Toilet Compartments (Near 1st and 2nd Floor Lobbies)	<ol style="list-style-type: none"> <li>1. Accessible stall &lt; 5'-0" wide.</li> <li>2. Doors &lt; 32" wide clearance.</li> <li>3. Soap dispenser &lt; 44" above floor (2nd floor).</li> <li>4. No pipe insulation under lavatories.</li> </ol>	<ol style="list-style-type: none"> <li>1. Remove toilet fixture and partitions to provide accessible restroom. (Men's and women's public restrooms on first and second floors)</li> <li>2. Insulate pipes under sink.</li> </ol>	3	RR2	\$ 12,000		
18	604: Water Closets & Toilet Compartments (all other restrooms)	<ol style="list-style-type: none"> <li>1. No 5'-0" turning radius.</li> <li>2. Size and layout of toilet compartments.</li> <li>3. No grab bars.</li> <li>4. Doors &lt; 32" wide clearance.</li> </ol>	<ol style="list-style-type: none"> <li>1. Convert men's restroom (upstairs) to accessible restroom. Remove urinal and toilet partition.</li> <li>2. Remove and replace 24" door with 36" door.</li> </ol>	3	RR3 DO2	\$ 4,500		

**REPORT TOTAL: \$ 62,850**