











I. G. LEVY MEMORIAL PARK
TENNIS AREA
 3900 CHICOT ST.

TRANSITION PLAN

ITEM #	SECTION #: GROUP	NON-COMPLIANCE DESCRIPTION	COMMENTS / SUGGESTED CORRECTIONS	PRIORITY	COST CODE	BUDGET COST	COMPL. DATE	PHOTOGRAPHS
1	206: Accessible Route	1. No accessible route between handicap parking located near playground restrooms and I. G. Levy Tennis area. 2. Access drive at sidewalk change in elevation > 1/4". 3. Bushes have grown over the sidewalk making it non-accessible.	<u>Option 1:</u> 1. Provide sidewalk from existing accessible parking spaces to tennis courts. <u>Option 2:</u> 2. Provide new ADA van accessible parking space at drive and sidewalk near tennis courts. Include re-striping and ADA signs. 3. Remove and replace drive cut. 4. Remove chain at bollards and provide (3) new removable bollards. 5. Trim bushes at East side of raquet ball building.	1	PK4 BOL1 DRI SW1	\$ 3,500		
2	403: Walking Surface	1. Change in elevation > 1/4". 2. 2 x 4 expansion joints and sidewalks create gaps which are non-compliant (multiple locations). 3. Uneven sidewalk expansion joints (multiple locations).	1. Remove and replace expansion joint material where it is recessed > 3/8" (±50 L.F.) 2. Grind high side of uneven sidewalk joints. (±25 L.F.)	1	EJ1	\$ 850		
3	303: Changes in Level	1. Non-compliant change in level between building patio and approaching sidewalk.	1. Grind high side of building patio and sidewalk. (±6 L.F.)	1	SW2	\$ 250		
4	206: Accessible Route	1. No accessible route to pavilion adjacent to tennis courts.	1. Provide 4' wide sidewalk to pavilion and grill area. (±60 L.F.)	2	SW1	\$ 2,400		
5	206: Accessible Route	1. Doors sizes are non-compliant at racquetball courts.	1. Provide one (1) court with a new 3070 door.	2	DRI	\$ 1,800		

I. G. LEVY MEMORIAL PARK
TENNIS AREA
 3900 CHICOT ST.

TRANSITION PLAN

ITEM #	SECTION #: GROUP	NON-COMPLIANCE DESCRIPTION	COMMENTS / SUGGESTED CORRECTIONS	PRIORITY	COST CODE	BUDGET COST	COMPL. DATE	PHOTOGRAPHS
6	903: Benches	1. Wooden benches are non-compliant.	1. Provide compliant benches. (20% of 5 benches = 1 bench)	2	BCH	\$ 2,500		
7	602: Drinking Fountain	1. Fountain is protruding into restroom accessible route.	1. Remove drinking fountain, patch wall, and provide new hi-low fountain on east wall. Provide new concrete pad for fountain approach ± 25 S.F.	4	EDF1	\$ 2,000		
8	216: Signs	1. Signage directing to the restrooms is non-compliant.	1. Provide signage directing to restrooms, and signage at restrooms.	2	ES	\$ 500		
9	404: Doors, Doorways & Gates	1. Women's does not have the required 18" at the pull side of door. 2. Both men's and women's force required to open is > 5 lbs. 3. Women's door sticks badly. 4. Door hardware on two (2) office doors needs to be replaced with lever hardware.	1. Women's (removal of partition will correct 18" dimension see #10 below) 2. Adjust closure. 3. Replace hardware on two (2) office doors.	2	DR3	\$ 1,800		
10	603: Toilet Rooms	1. Toilet rooms are non-compliant due to lack of maneuvering room and spacing of the fixtures and accessories.	1. Remodel each restroom to single use. (2 restrooms) 2. Adjust positions and heights of soap and paper towel dispensers, mirror and lavatory.	3	TLT1	\$ 10,000		

REPORT TOTAL: \$ 25,600