












14TH STREET (FFCS MAP #13)

TRANSITION PLAN

ITEM #	LOCATION	SECTION #: GROUP	NON-COMPLIANCE DESCRIPTION	COMMENTS / SUGGESTED CORRECTIONS	PRIORITY	COST CODE	BUDGET COST	COMPL. DATE	PHOTOGRAPHS
1	Sta. 0+00 14th St. @ Ingalls Ave. intersection	R207: Curb Ramps	1. No curb ramps 2. No access to pedestrian signal controls.	1. Provide curb ramps. 2. Provide access to pedestrian signal controls. 3. Coordinate utility locations. (Not included in Budget Costs)	1	CR4B	\$ 750		
2	Sta. 0+00 to 47+00 Intersecting streets: Ingalls Ave. to Old Mobile Hwy., east side of street	R204.2: Sidewalks R302.3: Sidewalk Width 5'-0" Min. R302.4: Passing Spaces R302.7.2: Change in Elevation R304.5.3: Cross Slope	1. Sidewalk width < 5'-0" 2. Cross slope > 2% 3. Vegetation/grass encroachment	1. Remove and replace sidewalk. (±4,120 L.F.) 2. Remove and replace drive ramps. (34) 3. Remove vegetation/grass encroachment.	3	SW1 DR4	\$ 285,000		
3	Sta. 9+50 14th St. @ Wilson Ave. intersection	R207: Curb Ramps	1. No curb ramps 2. No crosswalk markings	1. Provide curb ramps to north and south corners. 2. Provide crosswalk markings.	1	CR4B CW1	\$ 2,580		
4	Sta. 20+00 14th St. @ Happy Ave. intersection	R207: Curb Ramps R302.3.1: Cont. Width 5'-0" Min. R302.7.2: Change in Elevation R304.2: Perpend. Curb Ramps R304.2.1: Turning Space R305: Detec. Warning Surfaces	1. Curb ramp width < 5'-0" 2. No detectable warning surfaces 3. Vertical alignment > 1/4" 4. No crosswalk markings	1. Provide curb ramps to north and south corners. 2. Provide crosswalk markings.	1	CR4B CW1	\$ 2,580		
5	Sta. 33+50 14th St. @ Convent Ave. intersection	R207: Curb Ramps R302.3.1: Sidewalk Width 5'-0" Min. R302.6: Cross Slope R302.7.2: Change in Elevation R304.2.1: Turning Space R305: Detec. Warning Surfaces	1. Cross slope > 2% 2. Curb ramp width < 5'-0" 3. Vertical alignment > 1/4" 4. No crosswalk markings	1. Provide curb ramps to north and south corners. 2. Provide crosswalk markings.	1	CR4B CW1	\$ 2,580		
6	Sta. 36+75 14th St. @ Jackson Ave. intersection	R207: Curb Ramps	1. No curb ramps 2. No crosswalk markings	1. Provide curb ramps to north and south corners. 2. Provide crosswalk markings.	1	CR4B CW1	\$ 2,580		

14TH STREET (FFCS MAP #13)

TRANSITION PLAN

ITEM #	LOCATION	SECTION #: GROUP	NON-COMPLIANCE DESCRIPTION	COMMENTS / SUGGESTED CORRECTIONS	PRIORITY	COST CODE	BUDGET COST	COMPL. DATE	PHOTOGRAPHS
7	Sta. 47+50 to 82+91 Intersecting streets: Old Mobile Hwy. to Telephone Rd., east and west sides of street	R204.2: Sidewalks		1. No sidewalks.					
8	Sta. 47+50 14th St. @ Old Mobile Hwy. intersection (NW corner)	R207: Curb Ramps R302.7.2: Change in Elevation R304.2.1: Turning Space R305: Detec. Warning Surface	1. No access to pedestrian signal controls 2. No crosswalk markings east and south 3. No detectable warning surface 4. Vertical alignment > 1/4"	1. Remove and replace curb ramp east and south. 2. Provide access to pedestrian signal controls. 3. Provide crosswalk markings east and south.	1	CR CW1	\$ 3,500		
9	Sta. 47+50 14th St. @ Old Mobile Hwy. intersection (NE corner)	R302.3.1: Cont. Width 5'-0" Min. R302.7.2: Change in Elevation R304.2.1: Turning Space	1. No access to pedestrian signal controls 2. No crosswalk markings 3. Vertical alignment > 1/4"	1. Remove and replace curb ramp west and south. 2. Provide access to pedestrian signal controls. 3. Provide crosswalk markings. (See item 8 above and item 10 below)	2	CR CW1	\$ 3,500		
10	Sta. 47+50 14th St. @ Old Mobile Hwy. intersection (SE corner)	R207: Curb Ramps	1. No curb ramps 2. No access to pedestrian signal controls 3. No crosswalk markings north and west	1. Provide curb ramps north and west. 2. Provide access to pedestrian signal controls. 3. Provide crosswalk markings north and west.	1	CR CW1	\$ 3,500		
11	Sta. 47+50 14th St. @ Old Mobile Hwy. intersection (SW corner)	R403 & R404: Accessible pedestrian signals	1. No access to pedestrian signal controls	1. Provide access to pedestrian signal controls from parking lot. 2. Provide curb ramp accessible to parking lot.	2	PS1	\$ 2,000		

PLAN TOTAL: \$ 308,570